



What's That Transmission Line Worth?

**Using AURORAxmp to
Evaluate Transmission Expansion**

**September 10, 2008
2008 Electric Market Forecasting Conference
Stevenson, WA**

Presentation Outline

- I. Problem Formulation
- II. Valuation Methodology
- III. Implementation using AURORAxmp
- IV. Select Study Results
- V. Conclusions



Problem Formulation

Suppose ...

**that a developer has
proposed a new
transmission project**

- 500 kV line between Wyoming and Southern Nevada
- Paintbrush Powerlink Project (named after Wyoming's state flower)



Problem Formulation



Problem Formulation

- **The project is being advanced on the premise that there is an economic opportunity, i.e. that it would:**
 - Facilitate export of lower cost power to higher cost power areas
 - Facilitate large-scale development of the local resource potential
 - Facilitate lower cost compliance of state renewable portfolio standards (RPS), after accounting for system integration costs, line losses, and shaping
 - Provide other benefits such as improvements in grid reliability, fuel diversification, security of supply, etc.



Problem Formulation

- **Different analyses are needed to persuade different stakeholders:**
 - Creation of shareholder value
 - Ratepayer savings (ratepayers)
 - Regional market arbitrage opportunities (would-be usage rights holders)
 - Consistency with policy objectives and compliance with policy measures (policy-makers and regulators)
 - Environmental (air, land use, water, and vegetation and wildlife) benefits (environmental groups and siting and permitting agencies)



July 19, 2008

Texas Approves a \$4.93 Billion Wind-Power Project

Problem Formulation

FitchRatings
KNOW YOUR RISK

Corporate Finance

Global Power/North America
Special Report

Frayed Wires: U.S. Transmission System Shows Its Age

Analysts

Karen L. Anderson
+1 312 368-3165
karen.anderson@fitchratings.com

Denise Furey
+1 212 908-0672
denise.furey@fitchratings.com

Karima Omar
+1 212 908-0592
karima.omar@fitchratings.com

■ Overview

The U.S. electric transmission system consists of more than 150,000 miles of high-voltage transmission lines that link generators to load centers within three major regions — the Eastern Interconnection, the Western Interconnection and the Electric Reliability Council of Texas (ERCOT). Within these interconnections, more than 140 control areas manage electricity operations for local areas and coordinate reliability through eight reliability councils. The network was built in large part



United States Department of Energy
Office of Public Affairs
Washington, DC 20585

NEWS MEDIA CONTACT:
Julie Ruggiero, (202) 586-4940

FOR IMMEDIATE RELEASE
Tuesday, October 2, 2007

DOE Designates Southwest Area and Mid-Atlantic Area National Interest Electric Transmission Corridors

WASHINGTON, DC – U.S. Department of Energy (DOE) Assistant Secretary for Electricity Delivery and Energy Reliability Kevin M. Kolevar today announced the Department's designation of two National Interest Electric Transmission Corridors (National Corridors) -- the Mid-Atlantic Area National Interest Electric Transmission Corridor, and the Southwest Area National Interest Electric Transmission Corridor. These corridors include areas in two of the Nation's most populous regions with growing electricity congestion problems. The Department based its designations on data and analysis showing that persistent transmission congestion exists in these two areas.



Powerlines plan a must Build top five projects or risk huge losses


Paul Luke
The Province

Tuesday, July 22, 2008

Failure to build the top five planned transmission-line projects in the Pacific Northwest could cost the region \$55 billion to \$85 billion annually in economic activity and nearly 1.8 million jobs over 30 years, a new report says.

The region will also face a greater likelihood of rolling brownouts or blackouts from congestion of the existing grid if the lines don't proceed, according to the report released yesterday at a meeting of the Pacific NorthWest Economic Region in Vancouver.

Competition would not be strong enough to keep regional power costs down and ratepayers would have a higher likelihood of rate increases if the lines were not built,



CREDIT:
Additional trans
to ensure conti
the Pacific Nort

with in the region is over

fruition, the added pow
tion increase, assuming

five are the Alberta to P
Southern Crossing and


economic loss of \$15 bil
obs over 30 years if just
greatest economic impact



Power line benefits downsized; project expected to save customers \$85 million a year, not \$447 million

Problem Formulation

AEP'S CONCEPTUAL PLAN TO ACCOMMODATE 400 GW OF WIND ENERGY



WIND POWER CLASSIFICATION

Wind Power Class	Resource Potential
3	Fair
4	Good
5	Excellent
6	Outstanding
7	Superb

Conceptual 765 kV Network

- Existing 765 kV
- New 765 kV
- AC-DC-AC Link

Source: American Electric Power (AEP)



Valuation Methodology

- **For the purposes of this study, our focus is on demonstrating value to the ratepayer, e.g., as part of a CPCN application**
- **We further focus on one piece of the value proposition: the potential benefits associated with facilitating export of low cost power and increasing grid efficiency**
 - We will refer to these benefits as energy benefits
- **We will not consider the larger benefit set, nor the costs, of our hypothetical transmission project**
 - Energy benefits are additive to any other quantifiable benefits (such as those that might be had by facilitating lower cost achievement of state RPS targets)
 - The total expected project benefits can then be compared against the cost of developing the transmission project (and expected O&M)



Valuation Methodology

- **We will look at a change in cost to load (i.e. consumer surplus) to all U.S. ratepayers within the WECC**
 - Cost To Load = $\text{SUM} (\text{Load}_i * \text{LMP}_i)$ for load bus $i=1, \dots, n$ in WECC
 - We will not consider changes in generator profitability or changes in congestion costs as components of the PBPL energy benefit, although this could readily be done
- **Explore PBPL value over various futures through scenario and stochastic analysis**
 - We are -- in a sense -- trying to bridge the analytical gap between resource planning and transmission planning methods
 - For purposes of this study, we consider random forced outages and load volatility only




Valuation Methodology

- **We want to use a well calibrated zonal model as well as a more detailed network model**
- **The use of the network model allows for a better representation of the power flows in a transmission system**
 - In particular, want to explore benefits under N-1 conditions, i.e. via security constrained optimal power flow (SCOPF)
- **Explore one or more representative years, interpolate and extrapolate the rest**
 - Building a network model for each year of the study horizon would be extremely burdensome
 - The further one goes out the more grandiose the set of assumption
 - Likely to provide no more than an illusion of accuracy
- **Fruit of analysis is deterministic and stochastic expected energy benefits from PBPL**
 - Will not take further step to determine cost-effectiveness or explore alternatives



Implementation using AURORAxmp

- **We need a tool for our energy benefits analysis with the following capabilities:**
 - Network model and power flow optimization
 - Detailed generator representation for commitment and dispatch
 - Ability to treat key value drivers as random (stochastic) variables
 - Advanced data management capabilities and scenario handling
 - Quick simulation turn around times
 - A tried and true (i.e. proven) solution
- **What do you say,  ?**



Implementation using AURORAxmp

Open Save Run Step Pause Stop Scripting Status Input Data Run Setup Output Memory Compute System GIS Help

Save Change Set Show Used Tables View Zonal Nodal Action Reload Grid Save to DB Change DB Copy DB Force DB Load Save as XML Save to SQL Change F

- Change Sets
- [-] Network Updates
 - [-] Add Risk Parameters
 - [-] Resource Updates
 - Weekly Vectors
 - Monthly Shape Factors
 - Fuel Moderate
 - Resources
 - RMT WECC 2008_08_15
 - WECC Generator Map 20071
 - [-] Network Upgrades plus PBPL
 - WECC Supplemental Branch
 - WECC Corridor Limits
 - WECC Corridor Definition
 - Link
 - Annual Alpha Vectors
 - WECC Contingency 2008083
 - Unassigned Changes

Nodal Input Data Tables

AURORA Table Type	Required	In Study	Database Table Name	In DB	Status	# of Record
Aggregate Area	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	WECC US Aggregate 20071101	<input checked="" type="checkbox"/>	Read	3
	<input checked="" type="checkbox"/>	<input type="checkbox"/>	East Aggregate 20080617	<input checked="" type="checkbox"/>	Not Read	
	<input checked="" type="checkbox"/>	<input type="checkbox"/>	ERCOT Aggregate 20071101	<input checked="" type="checkbox"/>	Not Read	
AURORA Zone Map	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	WECC US ZoneMap 20071101	<input checked="" type="checkbox"/>	Read	34
	<input checked="" type="checkbox"/>	<input type="checkbox"/>	ERCOT Zone Map 20071101	<input checked="" type="checkbox"/>	Not Read	
	<input checked="" type="checkbox"/>	<input type="checkbox"/>	East ZoneMap 20080617	<input checked="" type="checkbox"/>	Not Read	
Contingency	<input type="checkbox"/>	<input type="checkbox"/>	ERCOT Contingency	<input checked="" type="checkbox"/>	Not Read	
	<input type="checkbox"/>	<input type="checkbox"/>	East Contingency 20080617	<input checked="" type="checkbox"/>	Not Read	
	<input type="checkbox"/>	<input checked="" type="checkbox"/>	WECC Contingency 20080830	<input checked="" type="checkbox"/>	Read	324
Corridor Def	<input type="checkbox"/>	<input checked="" type="checkbox"/>	WECC Corridor Definition	<input checked="" type="checkbox"/>	Read	171
	<input type="checkbox"/>	<input type="checkbox"/>	ERCOT Corridor Definition	<input checked="" type="checkbox"/>	Not Read	
	<input type="checkbox"/>	<input type="checkbox"/>	East Corridor Defs 20080617	<input checked="" type="checkbox"/>	Not Read	
Corridor Limit	<input type="checkbox"/>	<input checked="" type="checkbox"/>	WECC Corridor Limits	<input checked="" type="checkbox"/>	Read	43
	<input type="checkbox"/>	<input type="checkbox"/>	ERCOT Corridor Limits	<input checked="" type="checkbox"/>	Not Read	
	<input type="checkbox"/>	<input type="checkbox"/>	East Corridor Limits 20080617	<input checked="" type="checkbox"/>	Not Read	
FTR Reporting	<input type="checkbox"/>	<input type="checkbox"/>	FTR Reporting	<input checked="" type="checkbox"/>	Not Read	
Gen Map	<input type="checkbox"/>	<input type="checkbox"/>	WECC Generator Map 20071101	<input checked="" type="checkbox"/>	Read	2796
	<input checked="" type="checkbox"/>	<input type="checkbox"/>	ERCOT Generator Map 20071101	<input checked="" type="checkbox"/>	Not Read	

Setting Up the Nodal Analysis

Network Definition Datasets

Network Definition ID	Network Definition Dataset File	Start Date	PTDF File	PTI
WEC07	C:\x_Training\Skamania_2008\WECC_2007v032808.alfc	1/1/2015		Sol

Branch Set ID	Flow Limit	Counterflow Limit
Bonanza West	785	785
Borah West	2557	2557
Bridger West	2200	2200
Cholla - Pinnacle Peak	1200	1200
COI	4700	3675
Coronado West	1100	1100
CRYSTAL - ALLEN	950	950
East of Colorado River (EOR)	10500	10500
El Dorado - Mead	1140	1140
ELDORADO - MCCULLOUGH 500 KV	2598	2598
Four Corners 345/500 Auto	840	840
Idaho - Sierra	500	360
Idaho to Northwest	1200	2400
IID - SCE	1500	1500
INTERMOUNTAIN - GONDER 230 KV	200	200
INTERMOUNTAIN - MONA 345 KV	1400	1200
IPP DC LINE	1920	1400
Midway - Los Banos	5400	5400
Montana - NW	1350	2200
North of John Day	8400	8400
North of San Onofre	2440	2440
Northern - Southern California	4000	4000
Path	1000	1000
PERKINS - MOUNTAIN	1400	1400
PERKINS - MOUNTAIN	1400	1400
Perkins - Mead	1400	1400
PG&E	1500	1500
South of San Onofre	2500	2500

Active	Branch Set ID	From Bus Number	To Bus Number	Primary Key
<input checked="" type="checkbox"/>	Bonanza West	65520	-66590	13
<input checked="" type="checkbox"/>	Borah West	60005	-60060	14
<input checked="" type="checkbox"/>	Borah West	60006	-60060	15
<input checked="" type="checkbox"/>	Borah West	60060	65135	16
<input checked="" type="checkbox"/>	Borah West	60020	65920	17
<input checked="" type="checkbox"/>	Borah West	60020	60295	18
<input checked="" type="checkbox"/>	Bridger West	60060	-60090	19
<input checked="" type="checkbox"/>	Bridger West	60091	60190	20
<input checked="" type="checkbox"/>	Bridger West	60092	65665	21
<input checked="" type="checkbox"/>	Cholla - Pinnacle Peak	14100	14102	22
<input checked="" type="checkbox"/>	Cholla - Pinnacle Peak	14100	14103	23
<input checked="" type="checkbox"/>	COI	30005	-40702	24
<input checked="" type="checkbox"/>	COI	30005	-40706	25
<input checked="" type="checkbox"/>	COI	30020	-45044	26
<input checked="" type="checkbox"/>	Coronado West	14000	-15001	27
<input checked="" type="checkbox"/>	Coronado West	15001	15041	28
<input checked="" type="checkbox"/>	CRYSTAL - ALLEN	18014	18019	29
<input checked="" type="checkbox"/>	East of Colorado River (EOR)	14019	26123	30
<input checked="" type="checkbox"/>	East of Colorado River (EOR)	14021	24042	31
<input checked="" type="checkbox"/>	East of Colorado River (EOR)	15025	24801	32
<input checked="" type="checkbox"/>	East of Colorado River (EOR)	15034	19040	33
<input checked="" type="checkbox"/>	East of Colorado River (EOR)	15091	22536	34
<input checked="" type="checkbox"/>	East of Colorado River (EOR)	19058	19315	35
<input checked="" type="checkbox"/>	El Dorado - Mead	19012	24041	36
<input checked="" type="checkbox"/>	ELDORADO - MCCULLOUGH 500 KV	24042	26048	37
<input checked="" type="checkbox"/>	Four Corners 345/500 Auto	14001	14101	38
<input checked="" type="checkbox"/>	Idaho - Sierra	60235	64061	39

Implementation using AURORAxmp

Define interfaces ("Corridors") and set corresponding limits

Implementation using AURORAxmp



Contingency ID	Contingency Type	Equip ID	Enable
ELDORDO-LUGO_500kV	Branch	24086_24117_1	<input checked="" type="checkbox"/>
LUGO-MOHAVE_500kV	Branch	24097_24166_1	<input checked="" type="checkbox"/>
MOHAVE-ELDORDO_500kV	Branch	24042_24097_1	<input checked="" type="checkbox"/>
MEAD-MARKETPL_500kV	Branch	19038_26044_1	<input checked="" type="checkbox"/>
ELDORDO-MCCULLGH_500kV	Branch	24042_26048_1	<input checked="" type="checkbox"/>
MARKETPL-MCCULLGH_500kV	Branch	26044_26048_1	<input checked="" type="checkbox"/>
MCCULLGH-VICTORVL_500kV	Branch	26050_26105_1	<input checked="" type="checkbox"/>
MCCULLGH-VICTORVL2_500kV	Branch	26056_26105_2	<input checked="" type="checkbox"/>
BRIDGER-BORAH_345kV	Branch	60060_60090_1	<input checked="" type="checkbox"/>
PALOVR-DEVERS_500kV	Branch	15025_24801_1	<input checked="" type="checkbox"/>
NAVAJO-CRYSTAL_500kV	Branch	14019_26123_1	<input checked="" type="checkbox"/>
MOENKOPI-ELDORDO_500kV	Branch	14021_24042_1	<input checked="" type="checkbox"/>
MOENKOPI-FOURCO_500kV	Branch	14002_14010_1	<input checked="" type="checkbox"/>
MOENKOPI-NAVAJO_500kV	Branch	14002_14012_1	<input checked="" type="checkbox"/>
PERKINS-MEAD_500kV	Branch	15034_19040_1	<input checked="" type="checkbox"/>
BRIDGER-GOSHEN_345kV	Branch	60092_65665_1	<input checked="" type="checkbox"/>
CHOCOMA-PHUK-SHAY_500kV	Branch	14100_14102_1	<input checked="" type="checkbox"/>

Define contingencies (N-1)
for SCOPF

SCOPF study: No single element loaded (1) above its normal continuous thermal rating under pre-contingency conditions or (2) above its emergency ratings under contingency conditions




Implementation using AURORAxmp




Nodal: Another AURORAxmp Study Type

- Zonal to Nodal Data Transfer
- Flexibility without Complexity

Implementation using AURORAxmp




- **1500 MW of new Wyoming resources**
- **Otherwise WECC Long-Term expansion consistent with default Resource Modifier Table (RMT) from North American 2008-02 Database Release**




Implementation using AURORAxmp


Random forced outages on baseload units (nuclear, coal, CCGT)



Implementation using AUORAxmp



Implementation using AUORAxmp





Implementation using AURORAxmp


- **Change Sets used to manage data changes**
 - Second Network Definition file (.alfc) that includes the PBPL project
- **Power Transfer Distribution Factors (PTDFs) computed once and saved to file for re-use in stochastic studies**
- **Reporting Template SQL queries used to compute CTL and other outputs of interest**




Select Study Results




Average Annual Price Contour (Heat) Map – PBPL



Select Study Results




Select Study Results



Select Corridor (Interface) Flows – PBPL & Sans PBPL



Select Study Results



Cost to Load by LF Area - PBPL vs Sans PBPL

Select Study Results

Estimated Annual Energy Benefits* (\$000)

	Zonal	Nodal	
		N-0	N-1
Deterministic	228,405	274,366	259,772
Stochastic	(51,638)		331,128

* Change in CTL for WECC excluding California, Alberta, BC, and Baja California



Conclusions

- **We want to understand the potential economic benefit from a new transmission line**
- **AURORAxmp can be used as an important component of the analysis tool set**
 - Network model and power flow optimization
 - Detailed generator representation for commitment and dispatch
 - Ability to treat key value drivers as random (stochastic) variables
 - Advanced data management capabilities and scenario handling
 - Quick simulation turn around times
 - Tried and true (i.e. a proven solution)



Conclusions

- **Nodal analysis allows opportunity for valuable insights**
 - However, many detailed assumptions need to be made
 - Large effort is required to develop and validate data assumptions
 - Garbage in, garbage out
 - Illusion of accuracy
 - As much as possible best to rely on existing regional planning efforts, e.g. TEPPC in WECC, for long-term analyses
- **Data and scenario management**
 - Efficient input and output data management is critical for successful analysis
 - Hourly output valuable but costly to report in terms of run time and disk space
 - Can easily get over 40 billion output records and large databases (e.g. 10 GB)
 - However, this should not be used as an excuse to avoid detailed validation of results
 - Memory tables can help in this regard
 - Use SQL Server (or MySQL) to facilitate queries and custom templates to explore assumptions and results



Conclusions

- **More analytical opportunities not considered in this study**
 - Transmission expansion & LT Capacity Expansion
 - LT analysis can reflect transmission expansion assumptions and therefore provide a consistent set of resource and transmission expansion results
 - LT, however, limited to zonal analysis
 - RPS compliance cost benefits
 - Could be assessed using AURORAxmp*
 - Emissions
 - Enhanced stochasticity
 - All key drivers represented
 - Choice of number of iteration based on statistical tests
 - Short- and long-term (two-factor) processes
 - Line loss modeling





What's That Transmission Line Worth?

**Using AURORAxmp to
Evaluate Transmission Expansion**

